



Partnership network of
Rescue departments in Finland

Self-assessment form for fire safety in detached and other small houses

Address of the property

Postal Code

City/town

Telephone number

Email address

The building is in residential use

leisure use

unoccupied/empty

business use

(fill in the details to the "additional information" field below)

Guide page no.	Matter to be checked	To be fixed	In order/ fixed	Does not concern building
2-3	There is at least one properly located smoke alarm for each 60 m ² on every floor	<input type="checkbox"/>	<input type="checkbox"/>	
2	Smoke alarms are tested regularly, batteries replaced when necessary, and smoke alarms at the end of their useful life are replaced	<input type="checkbox"/>	<input type="checkbox"/>	
4-6	Electrical appliances are used safely in accordance with instructions	<input type="checkbox"/>	<input type="checkbox"/>	
6	Sauna is used in accordance with fire safety regulations	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	There is a safe exit route from every floor of the house	<input type="checkbox"/>	<input type="checkbox"/>	
9	Escape doors and windows are easy to open and equipped with fixed opening handles	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	Equipment and chimneys on the roof are easily and safely accessible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Fireplaces and smoke flues, which are currently being used, have been swept	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Safety distance from fireplace to flammable materials is sufficient	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Flammable liquids and gases are stored according to regulations	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Underground oil tanks located in groundwater area have been inspected within the set period of time	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Safety distance of waste containers and shelters from buildings is sufficient, or they have been separated by compartment walls as required	<input type="checkbox"/>	<input type="checkbox"/>	
12	Flammable material is not stored in the immediate vicinity of the building	<input type="checkbox"/>	<input type="checkbox"/>	
13	The house number sign is large enough and it can be seen from the street even in the dark	<input type="checkbox"/>	<input type="checkbox"/>	
13	Fire compartmentation of the boiler room is tight (fire-rated door, ducts)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Voluntary improvement of safety

Fixed

2-3 A smoke detector has been installed in all bedrooms and on routes leading outdoors

7 Sufficient emergency supplies are being maintained in case of disruptions

8 The house is equipped with first aid firefighting equipment

Additional information (e.g. schedule for repairs of deficiencies detected)

Deficiencies detected during self-assessment will be fixed by (ddmmyy)

Further information on a separate paper/file

To be filled by the rescue authority:

The form was examined on

Date

Rescue authority

Need for a separate fire inspection

Yes No

I hereby confirm that the information I have provided is true and correct:

Date

Signature and name in block letters

The rescue authority will enter the necessary information into the supervision register referred to in section 93 of the Rescue Act.