

## SUMMARY

No. 2230820/5

Only valid in combination with the ISP GmbH test report no. 2230820/5, dated 16.10.2020.

**Type of Testing:** Performance Testing of a ceiling system in accordance with DIN 18032-3, the German standard for sport halls, part 3: Halls for gymnastics, games and multi-purpose-use, testing of safety against ball throwing (2018)

**Applicant:** Cewood SIA  
Galdusalas 1  
04336 Jaunlaicene  
Latvia

**Test Institute:** ISP GmbH  
Institut für Sportstättenprüfung  
Amelunxenstraße 65  
48167 Münster  
Germany

**Product Name:** Cewood System Ball Impact Metal

**Description:** WW ceiling panels with the dimensions (length x width x height) of approx. 1200 mm x 600 mm x 35 mm and approx. 600 mm x 600 mm x 35 mm with a metal substructure

**Test Results:** The ceiling system “Cewood System Ball Impact Metal” withstood the testing of safety against ball throwing with marginal visual changes. Therefore, the system is classed as **safe against ball throwing for ceiling elements in accordance with 18032 part 3 (November 2018) (ballwurfsicher für Deckenelemente)**.

Reproduction and publication of this document in shortened text and the use of advertising is permitted only with the written approval of the ISP GmbH.

The test results relate only to the tested samples.

Münster, 16.10.2020



Dennis Frank  
MANAGING DIRECTOR

**ADDRESS**

ISP GmbH  
Amelunxenstraße 65  
48167 Münster  
Germany

**CONTACT**

T +49 (0) 2506 30 77 000  
info@isp-germany.com  
www.isp-germany.com

**BANK DETAILS**

Vereinigte Volksbank Münster eG  
SWIFT-BIC GENODEM1MSC  
IBAN DE57 4016 0050 0084 6989 00

**MANAGEMENT**

Dennis Frank  
**COMMERCIAL REGISTER**  
HRB 208985  
Local Court of Osnabrück

**TAX NUMBER**

337 / 5945 / 0518  
VAT No. DE297978054