

SUMMARY

No. 2230820/6

Only valid in combination with the ISP GmbH test report no. 2230820/6, dated 16.10.2020.

Type of Testing: Performance Testing of a ceiling inspection clap in accordance with DIN 18032-3, the German standard for sport halls, part 3: Halls for gymnastics, games and multi-purpose-use, testing of safety against ball throwing (2018)

Applicant: Cewood SIA
Galdusalas 1
04336 Jaunlaicene
Latvia

Test Institute: ISP GmbH
Institut für Sportstättenprüfung
Amelunxenstraße 65
48167 Münster
Germany

Product Name: Cewood System Ball Impact Inspection Clap

Description: Ceiling inspection clap with the dimensions (length x width) of approx. 400 mm x 400 mm that has been installed into the "Cewood System Ball Impact" system, consisting of WW ceiling panels.

Test Results: The inspection clap "Cewood System Ball Impact Inspection Clap" withstood the testing of safety against ball throwing with marginal visual changes. Therefore, the system is classed as **safe against ball throwing for ceiling elements in accordance with 18032 part 3 (November 2018) (ballwurfsicher für Deckenelemente)**.

Reproduction and publication of this document in shortened text and the use of advertising is permitted only with the written approval of the ISP GmbH.

The test results relate only to the tested samples.

Münster, 16.10.2020



Dennis Frank
MANAGING DIRECTOR

ADDRESS

ISP GmbH
Amelunxenstraße 65
48167 Münster
Germany

CONTACT

T +49 (0) 2506 30 77 000
info@isp-germany.com
www.isp-germany.com

BANK DETAILS

Vereinigte Volksbank Münster eG
SWIFT-BIC GENODEM1MSC
IBAN DE57 4016 0050 0084 6989 00

MANAGEMENT

Dennis Frank
COMMERCIAL REGISTER
HRB 208985
Local Court of Osnabrück

TAX NUMBER

337 / 5945 / 0518
VAT No. DE297978054